

*Attn: Salley*



RECEIVED  
N.C. Dept. of EHNR

DEC 16 1993

Winston-Salem  
Regional Office

State of North Carolina  
Department of Environment, Health, and Natural Resources  
Winston-Salem Regional Office

James G. Martin, Governor  
William W. Cobey, Jr., Secretary

Margaret Plemmons Foster  
Regional Manager

DIVISION OF ENVIRONMENTAL MANAGEMENT  
GROUNDWATER SECTION

*March 14, 1994*

*C. W. Myers  
2718 P. Liberty St.  
Winston-Salem, NC 27104*

Dear *Sam*

This letter is to acknowledge your Notification of Tank Closure as received *March 3, 1994* and filed as *Old Service Station*. All future correspondence must contain the file name as well as address and county in the subject to ensure its receipt into our filing system.

The results of the required assessment (NCAC Title 15A Subchapter 2N Section .0803 and 40 CFR Part 280.72) should be submitted to this office no later than thirty (30) days after the tank is closed. If there is evidence of a release or suspected release, it must be reported within twenty-four (24) hours.

Groundwater Section staff will be conducting random site visits to ensure that underground storage tank closures are conducted as required in NCAC Title 15A Subchapter 2N Sections .0802 and .0803 and 40 CFR 280.71 and 280.72. Any violations documented may be submitted for enforcement action.

Enclosed is an attachment that is to be used for the information required for closure assessment. You may contact me at the letterhead address or telephone number if you have any questions concerning these requirements.

Sincerely,

*Thomas A. Salley*

Thomas A. Salley  
Hydrogeological Technician

TAS/ahl  
Enclosure  
cc: WSRO

*Joyner Wrecking & Grading Inc.*

8025 North Point Boulevard, Suite 100, Winston-Salem, NC 27106-320 • Telephone 919-761-2351